



Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8	36			Y
4					
5					
6					
7					
8					
9					
10	8	39			Y
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	8.2	41			Y
24					
25					
26					
27					
28	8.5	44			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION CO

**ENTRY POINT**  
**EP-A**  
**PWS ID 4193768**  
**ABIQUA SCHOOL**

Sample period: December 2021  
Month/Year

Number of excursions during this month

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which a water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State

pH 7.2  
Alk 30.0 (Alkalinity)

Print Name: Sharon Sauer  
Signature: [Signature]  
Date & Phone#: 1 Dec 21

Send to DWP within 10 days after end of sampling period

(0 = N = Excursion) Total N's 0