

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8	31			Y
2					
3					
4					
5					
6					
7					
8					
9					
10	7.7	33			Y
11					
12					
13					
14					
15					
16					
17	7.8	34			Y
18					
19					
20					
21					
22					
23	7.9	31			Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: May 22
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk 30.0 (Alkalinity)

Print Name: Shane Sancerro

Signature: [Signature]

Date & Phone#: May 22

Send to DWP within 10 days after end of sampling period

(0 = N = Excursion) Total N's 0