

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.8	32			N
2					
3					
4					
5					
6					
7	7.9	40			N
8					
9					
10					
11					
12					
13					
14					
15					
16	7.9	36			N
17					
18					
19					
20					
21					
22	7.8	36			N
23					
24					
25					
26					
27	7.9	34			N
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

Sample period: June 22  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 30.0 (Alkalinity)

Print Name: Shane Sanger

Signature: [Signature]

Date & Phone#: 27 June 22

Send to DWP within 10 days after end of sampling period

(0 = N = Excursion) **Total N's** 0