

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 7.4 | 32  |      |       | N   |
| 2   |     |     |      |       |     |
| 3   |     |     |      |       |     |
| 4   |     |     |      |       |     |
| 5   |     |     |      |       |     |
| 6   |     |     |      |       |     |
| 7   |     |     |      |       |     |
| 8   |     |     |      |       |     |
| 9   |     |     |      |       |     |
| 10  |     |     |      |       |     |
| 11  |     |     |      |       |     |
| 12  |     |     |      |       |     |
| 13  | 7.7 | 38  |      |       | N   |
| 14  |     |     |      |       |     |
| 15  |     |     |      |       |     |
| 16  |     |     |      |       |     |
| 17  |     |     |      |       |     |
| 18  |     |     |      |       |     |
| 19  |     |     |      |       |     |
| 20  | 7.6 | 41  |      |       |     |
| 21  |     |     |      |       |     |
| 22  |     |     |      |       |     |
| 23  |     |     |      |       |     |
| 24  |     |     |      |       |     |
| 25  |     |     |      |       |     |
| 26  |     |     |      |       |     |
| 27  | 7.1 | 38  |      |       | N   |
| 28  |     |     |      |       |     |
| 29  |     |     |      |       |     |
| 30  | 7.2 | 35  |      |       | N   |
| 31  |     |     |      |       |     |

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4193768**  
**ABIQUA SCHOOL**

Sample period: September 2020  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

|     |                   |
|-----|-------------------|
| pH  | 7.2               |
| Alk | 30.0 (Alkalinity) |

Print Name: Shane SANCEDO  
 Signature: [Signature]  
 Date & Phone#: Sept 28 775.230.3021

Send to DWP within 10 days after end of sampling period

(0 = N = Excursion) Total N's 0