

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	8.3	41			✓
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21	8.4	36			✓
22					
23					
24					
25					
26					
27	8.2	31			✓
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**



Sample period: Sept 2023  
 Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Sharon Sancesco

Signature: [Signature]

Date & Phone#: 27 Sept 23

Send to DWP within 10 days after end of sampling period

lo = N = Excursion) Total N's