Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ay	pH	Alk	Phos	Other	Y/N
	[illegible]	[illegible]			
	8.3	38			N
D	7.4	41			N
1					
2					
3					
4					
5					
6					
	7.3	57			N
	7.4	40			N

(N = Excursion) **Total N's** 4

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: Jan 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.2	
Alk	30.0	*(Alkalinity)*

Print Name: Shane Sanders

Signature: [signature]

Date & Phone#: 29 Jan 24

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/