

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.9	51			
6					
7					
8					
9					
10					
11					
12					
13					
14	7.7	66			
15					
16					
17					
18					
19					
20					
21	8	49			
22					
23					
24					
25					
26					
27					
28					
29	8.5	55			
30					
31					

lo = N = Excursion) Total N's

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

Sample period: March/2024  
Month/Year

Number of excursions during this month: \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Shane Sanchez

Signature: [Signature]

Date & Phone#: \_\_\_\_\_

Send to DWP within 10 days after end of sampling period