

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8.2	50			
4					
5					
6					
7					
8					
9					
10	7.9	51			
11					
12					
13					
14					
15					
16					
17					
18	7.7	49			
19					
20					
21					
22					
23					
24	8.1	44			
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

Sample period: June 24  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

*Reference*

Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 30.0 (Alkalinity)

Print Name: Shane Samard  
Signature: [Signature]  
Date & Phone#: 28 June 21

Send to DWP within 10 days after end of sampling period

lo = N = Excursion) Total N's 0