

| Day | pH | Alk | Phos | Other | Y/N |
|-----------|-----|-----|------|-------|-----|
| 1 | 8.0 | 46 | | | N |
| 2 | | | | | |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 7.5 | 38 | | | N |
| 9 | | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | | | | | |
| 14 | | | | | |
| 15 | 7.8 | 38 | | | N |
| 16 | | | | | |
| 17 | | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | 8.1 | 31 | | | N |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |
| Total N's | | | | | N |

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: Aug 2024
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

| | |
|-----|-------------------|
| pH | 7.2 |
| Alk | 30.0 (Alkalinity) |

Print Name: Shane Sanchez
 Signature: [Signature]
 Date & Phone#: 28 Aug 2024

Send to DWP within 10 days after end of sampling period