

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	8.8	36			N
6					
7					
8					
9					
10					
11					
12					
13	8.1	34			N
14					
15					
16					
17					
18					
19					
20	8.5	31			N
21					
22					
23					
24					
25					
26	9.8	36			N
27	8.8	36			N
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT
EP-A
PWS ID 4193768
ABIQUA SCHOOL

Sample period: Nov / 2024
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk 30.0 (Alkalinity)

Print Name: Shane Sanchez
 Signature: [Signature]
 Date & Phone#: 26 Nov 24

Send to DWP within 10 days after end of sampling period

lo = N = Excursion) Total N's 0

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	8.8	36			N
6					
7					
8					
9					
10					
11					
12					
13	8.1	34			N
14					
15					
16					
17					
18					
19					
20	8.5	31			N
21					
22					
23					
24					
25					
26	9.8	36			N
27	8.8	36			N
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT
EP-A
PWS ID 4193768
ABIQUA SCHOOL

Sample period: Nov / 2024
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Shane Sanchez
 Signature: [Signature]
 Date & Phone#: 26 Nov 24

Send to DWP within 10 days after end of sampling period

lo = N = Excursion) Total N's 0