

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	9.0	31			N
4					
5					
6					
7					
8					
9					
10					
11					
12	9.6	34			N
13					
14					
15					
16					
17					
18					
19	9.2	31			
20					
21					
22					
23					
24					
25					
26	9	31			
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Marion

Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: Feb 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2
Alk 30.0 (Alkalinity)

Print Name: Shane Sampedo

Signature: [Signature]

Date & Phone#: 26 Feb 25

Send to DWP within 10 days after end of
sampling period

lo = N = Excursion) Total N's N