

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	9.1	30			
4					
5					
6					
7					
8	9.0	31			
9					
10					
11					
12					
13					
14					
15					
16	9.1	31			
17					
18					
19					
20					
21					
22					
23	8.7	34			
24					
25					
26					
27					
28					
29					
30	9.0	30			
31					

lo = N = Excursion) Total N's

<<Have  
minimums  
been met for  
this day?

County: Marion

Agency: MARION COUNTY

**ENTRY POINT**

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: April 25  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

*Reference*

Minimum Water Quality  
Parameter(s) as set by State:

pH   
Alk  (Alkalinity)

Print Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Date & Phone#: \_\_\_\_\_

Send to DWP within 10 days after end of  
sampling period