

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	11	31			N
5					
6					
7					
8					
9					
10					
11					
12					
13					
14	9.9	30			N
15					
16					
17					
18					
19					
20					
21					
22	8.6	32			N
23					
24					
25					
26					
27	8.6	34			N
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion

Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

Sample period: June 25  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

Minimum Water Quality  
Parameter(s) as set by State:

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Shane Sanchez

Signature: [Signature]

Date & Phone#: 27 June 25

Send to DWP within 10 days after end of sampling period

10 = N = Excursion) Total N's 0