

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8.9	32			N
4					
5					
6					
7					
8					
9					
10	8.8	33			N
11					
12					
13					
14					
15					
16	8.8	35			N
17					
18					
19					
20					
21					
22					
23	9	31			N
24					
25					
26					
27					
28					
29					
30	9.1	32			
31					

<<Have  
minimums  
been met for  
this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

Sample period: July 25  
Month/Year

Number of excursions during this month: 8

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

**Reference**

**Minimum Water Quality  
Parameter(s) as set by State:**

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Shane Siquero  
Signature: [Signature]  
Date & Phone#: 3/July 25

Send to DWP within 10 days after end of  
sampling period

10 = N = Excursion) **Total N's** N