

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	8.2	34			
6					
7					
8					
9					
10					
11					
12					
13	8.5	34			
14					
15					
16					
17					
18					
19					
20					
21					
22	8.5	33			
23					
24					
25					
26					
27					
28	8.8	32			
29					
30					
31					

10 = N = Excursion) Total N's N

<<Have  
minimums  
been met for  
this day?

County: Marion

Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

Sample period: August 2025  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

### Reference

Minimum Water Quality  
Parameter(s) as set by State:

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Shane Sancedo

Signature: [Signature]

Date & Phone#: 28 Aug 25

Send to DWP within 10 days after end of  
sampling period