



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?
9	7.1				Y	
21	7.1				Y	
30	7.2				Y	

<<Have minimums been met for this day?

County: Clackamas Agency: Clackamas Count

ENTRY POINT

EP-A

PWS ID 4193970

CARUS ELEMENTARY

Sample period: June 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) set for this PWS:

pH 7.1

RECEIVED
JUL 13 2022

Data Mgmt & Compliance
Drinking Water Program

Print Name: Vladimir Tepzhetsov
Signature: [Signature]
Date: 6.30.22

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period