



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Silf	Y/N
8	7.1				Y
19	7.1				Y
31	7.1				Y

<<Have
 minimums
 been met for
 this day?

County: Clackamas Agency: Clackamas Count

ENTRY POINT

EP-A

PWS ID 4193970

CARUS ELEMENTARY

Sample period: March 2021
Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 cumulative). An 'excursion' is any day in which the
 water quality parameter(s) fall below the minimum
 set by the State.

RECEIVED

APR 05 2021

Data Mgmt & Compliance
Drinking Water Program

Reference

Minimum Water Quality
 Parameter(s) set for this PWS:

pH 7.1

Print Name: Vladimir Kuznetsov
 Signature: [Signature]
 Date: 3.31.21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period