



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?
5	7.1				Y	
14	7.2				Y	
27	7.1				Y	

<<Have minimums been met for this day?

County: Clackamas Agency: Clackamas Count

ENTRY POINT

EP-A

PWS ID 4193970

CARUS ELEMENTARY

Sample period: May 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Reference Data Mgmt & Compliance
Drinking Water Program

**Minimum Water Quality
Parameter(s) set for this PWS:**

pH

(No = N = Excursion) Total N's

Print Name: Vladimir Bygnetsov
Signature: [Handwritten Signature]
Date: 5.30.21