



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH   | Alk | Phos | Temp<br>Other | Y/N |
|-----|------|-----|------|---------------|-----|
| 1   |      |     |      |               |     |
| 2   |      |     |      |               |     |
| 3   |      |     |      |               |     |
| 4   |      |     |      |               |     |
| 5   |      |     |      |               |     |
| 6   |      |     |      |               |     |
| 7   |      |     |      |               |     |
| 8   |      |     |      |               |     |
| 9   | 7.54 |     |      | 19.8          | Y   |
| 10  |      |     |      |               |     |
| 11  |      |     |      |               |     |
| 12  |      |     |      |               |     |
| 13  |      |     |      |               |     |
| 14  |      |     |      |               |     |
| 15  |      |     |      |               |     |
| 16  |      |     |      |               |     |
| 17  |      |     |      |               |     |
| 18  |      |     |      |               |     |
| 19  |      |     |      |               |     |
| 20  |      |     |      |               |     |
| 21  |      |     |      |               |     |
| 22  | 7.47 |     |      | 18.6          | Y   |
| 23  |      |     |      |               |     |
| 24  |      |     |      |               |     |
| 25  |      |     |      |               |     |
| 26  |      |     |      |               |     |
| 27  |      |     |      |               |     |
| 28  |      |     |      |               |     |
| 29  |      |     |      |               |     |
| 30  |      |     |      |               |     |
| 31  |      |     |      |               |     |

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4194670**

**OREGON TRAIL SD - BORING MID SCH**

Sample period: 9/21  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Lance Brooks

Signature: Jane Brooks

Date & Phone#: 9-22-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>