

Lead & Copper Rule Corrosion Control

Temp

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.4			17°C	
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18	7.4			16°C	
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample period: 2/2024  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Chelsea Lincoln Lane

Signature: [Signature]

Date & Phone#: 2/29/24 503 608 6442

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0