

**Lead & Copper Rule Corrosion Control**

*Temp*

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9	7.4	120		18°C	Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	7.5	120		16°C	Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4194670**

**OREGON TRAIL SD - BORING MID SCH**

Sample period:

*June 2025*

Month/Year

Number of excursions during this month: *0*

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: *Chelsea Lincoln Lane*

Signature: *Chelsea*

Date & Phone#: *7/3/25*

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0