



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

TCWP
Offer

ID #	Sample Location	pH	Alk	PO4	TCWP Offer	Y/N
10/5/21	West Hall	7.39			18.6°C	Y
10/5/21	Rm 15	7.61			14.1°C	Y
10/19/21	West Hall	7.36			18.7°C	Y
10/19/21	Rm 15	7.49			15.9°C	Y

<Has sample met the minimum(s)?

County: Clackamas Agency: CLACKAMA

DISTRIBUTION

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample Period: 10/21
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Lance Brooks

Signature: Lance Brooks

Date: 10/19/21

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>