



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Date	ID#	Sample Location	pH	Alk	PO4	Temp Other	Y/N
11/21		West Hall	7.62			19.0°	Y
11/21		Rm # 15	7.19			15.0°	Y
11/21							
11/21		West Hall	7.34			18.6°	Y
11/21		Rm # 15	7.77			14.8°	Y
11/21							
11/21		West Hall	7.44			15.9°	Y
11/21		Rm # 15	7.65			12.4°	Y

<Has sample met the minimum(s)? County: Clackamas Agency: CLACKAMA

DISTRIBUTION

PWS ID 4194670
OREGON TRAIL SD - BORING MID SCH

Sample Period: 11/21
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Lance Brooks
Signature: Lance Brooks
Date: 11-30-21

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>