Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date ~~ID#~~	Sample Location	pH	Alk	PO4	Temp ~~other~~	Y/N
2/3/22	West Hall	7.59			14.9 C	Y
2/3/22	Rm # 15	7.75			12.0 C	
2/16/22	West Hall	7.30			15.5 C	Y
2/16/22	Rm # 15	7.61			11.2 C	Y
2/25/22	West Hall	7.67			15.2 C	Y
2/25/22	RM #15	7.65			9.38 C	Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Clackamas

Agency: CLACKAMA

DISTRIBUTION

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample Period: 2/22
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Lance Brooks

Signature: Lance Brooks

Date: 2/25/22

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

Received Time Feb. 25. 2022 7:04AM No. 8321