

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

temp

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
5/13/24	West Hall BF	7.5			16°C	
5/13/24	Room 15	7.4			17°C	
5/27/24	West Hall BF	7.6			15°C	
5/27/24	Room 15	7.3			17°C	

<Has sample met the minimum(s)?

County: Clackamas Agency: CLACKAMA

DISTRIBUTION

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample Period: May 2024
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0
(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Chelsea Lincoln Lane
 Signature: Chelsea
 Date: 6/4/2024

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>