Received Time Dec. 28. 2021 7:42AM No. 8138

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Date	Sample Location	pH	Alk	PO4	Temp Other	Y/N
12/7/21	West Hall	7.71			16.6°	Y
12/7/21	Rm # 15	7.65			12.8°	Y
12/7/21	West Hall	7.51			17.1°	Y
12/7/21	Rm # 15	7.67			13.7°	Y
12/29/21	West Hall	7.37			15.1°	Y
12/29/21	Rm # 15	7.28			11.8°	Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Clackamas

Agency: CLACKAMA

DISTRIBUTION

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample Period: 12/21
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Lance Brooks

Signature: Lance Brooks

Date: 12/28/21

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

04/28/2007 18:18 5036685291 BORING MIDDLE SCHOOL PAGE 02/02