



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Temp C/F	Y/N
9/1/22	West Hall	7.5			21.7	Y
9/1/22	Rm # 15	7.3			20.2	Y
9/16/22	West Hall	7.4			20.1	Y
9/16/22	Rm # 15	7.2			19.3	Y
9/30/22	West Hall	7.4			19.6	Y
9/30/22	Rm # 15	7.5			18.1	Y

(N = No = Excursion) Total N's 0

<Has sample met the minimum(s)?

County: Clackamas Agency: CLACKAMA

### DISTRIBUTION

**PWS ID 4194670**

**OREGON TRAIL SD - BORING MID SCH**

Sample Period: 9/22  
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

**Minimum Water Quality Parameters as set by State:**

pH 7.2

Print Name: Lance Brooks

Signature: Lance Brooks

Date: 9/30/22

Send to Drinking Water Program within 10 days after end of sampling period:  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>