



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

*Temp*

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
------	-----------------	----	-----	-----	-------	-----

<Has sample met the minimum(s)?	County: Clackamas     Agency: CLACKAMA  <h3 style="text-align: center;">DISTRIBUTION</h3>
---------------------------------	---

12/10/2023	West Hall BF	7.6			16°C	
12/10/2023	Room 15	7.4			21°C	
12/24/2023	West Hall BF	7.0			15°C	
12/24/2023	Room 15	7.3			22°C	

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample Period: 12/2024  
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion)     Total N's 0

Print Name: Chelsea Lincoln Larre

Signature: *Chelsea Larre*

Date: 12/31/23

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405     Website: <http://healthoregon.org/dwp/>