

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Temp

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
------	-----------------	----	-----	-----	-------	-----

	6/10/24 West Hall BF	7.5			15°C	
	6/10/24 Room 15	7.4			17°C	
	6/24/24 West Hall BF	7.3			16°C	
	6/24/24 Room 15	7.5			16°C	

<Has sample met the minimum(s)?

County: Clackamas Agency: CLACKAMA

DISTRIBUTION

PWS ID 4194670

OREGON TRAIL SD - BORING MID SCH

Sample Period: June 2024
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0
(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Chelsea Lincoln Lane
 Signature: *Chelsea*
 Date: 7/9/2024