

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16	7.75				Y
17					
18					
19					
20					
21					
22					
23	7.71				Y
24					
25					
26					
27					
28	7.77				Y
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4194717

COLUMBIA RIVER PUD



Sample period: July 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: TIM LAMMERS
Signature: [Signature]
Date & Phone#: 7-28-21 503.397.8155

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0