

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.63				Y
3					
4					
5					
6					
7					
8					
9	7.61				Y
10					
11					
12					
13					
14					
15	7.40				Y
16					
17					
18					
19					
20					
21					
22	7.82				Y
23					
24					
25					
26					
27					
28					
29					
30	7.64				Y
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4194717

COLUMBIA RIVER PUD

Sample period: August 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Lanny Lee

Signature: [Signature]

Date & Phone#: 9/1/22 503-366-9914

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0