

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.56				
5					
6					
7					
8					
9					
10					
11					
12					
13	7.82				
14					
15					
16					
17					
18					
19					
20					
21	7.69				
22					
23					
24					
25					
26					
27	7.68				
28					
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

PWS ID: 41

9 4 7 1 7

### ENTRY POINT

System Name: Columbia River Puget

Entry Point: \_\_\_\_\_

Sample Period: April 2023  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.2

Alk \_\_\_\_\_ (Alkalinity)

PO4 \_\_\_\_\_ (Orthophosphate)

Other \_\_\_\_\_ (\_\_\_\_\_)

Print Name: Car Hall 6.5

Signature: Car A Hall 6.5

Date: 5/2/2023

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0