

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.68				Y
3					
4					
5					
6					
7					
8					
9	7.69				Y
10					
11					
12					
13					
14					
15					
16	7.71				Y
17					
18					
19					
20					
21					
22					
23	7.76				Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 94717

System Name: Columbia River Pu d

Entry Point: _____

Sample Period: may 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other (_____)

Print Name: Greg Hollis

Signature: Gregory A Hollis

Date: 6/1/2023 503-320-7946

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0