

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.79				Y
4					
5	7.78				Y
6					
7					
8					
9					
10	7.94				Y
11					
12	7.93				Y
13					
14					
15					
16					
17	7.82				Y
18					
19	7.78				Y
20					
21					
22					
23					
24	7.85				Y
25					
26	7.88				Y
27					
28					
29					
30					
31	7.87				Y

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4194717

COLUMBIA RIVER PUD

Sample period: October 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Greg Hollis

Signature: Carey K Hollis

Date & Phone#: 10/1/2023 503-396-0529

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>