

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.76				Y
4					
5	7.81				Y
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16	7.80				Y
17					
18	7.68				Y
19					
20					
21					
22					
23	7.80				Y
24					
25	7.78				Y
26					
27					
28					
29					
30					
31	7.85				Y

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 94717

System Name: Columbia River Pwd

Entry Point: \_\_\_\_\_

Sample Period: Jan 2024  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.2  
Alk  (Alkalinity)  
PO4  (Orthophosphate)  
Other  (\_\_\_\_\_)

Print Name: Greg Hollis

Signature: Greg Hollis

Date: Feb 1 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>