

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.63				Y
5					
6	7.67				Y
7					
8					
9					
10					
11	7.67				Y
12	7.72				Y
13	7.69				Y
14					
15					
16					
17					
18	7.81				Y
19	7.73				Y
20	7.74				Y
21					
22					
23					
24	7.80				Y
25					
26	7.75				Y
27	7.80				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4194717**  
**COLUMBIA RIVER PUD**

Sample period: June 2024  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Greg Hollis

Signature: Greg Hollis

Date & Phone#: 7/1/2024 503-396-0529

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0