

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.93				Y
6					
7	7.95				Y
8					
9					
10					
11					
12					
13	7.90				
14					Y
15	7.84				Y
16					
17					
18					
19					Y
20	7.94				
21					
22					
23					
24					
25	7.71				Y
26					
27	7.70				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4194717

COLUMBIA RIVER PUD

Sample period: November 2024
 Month/Year

Number of excursions during this month: 6

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Print Name: Gregory A Hollis

Signature: Gregory A Hollis

Date & Phone#: 12/3/2024 503-396-0529

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's