

Day	pH	Alk	Phos	Other	Y/N
1	7.84				Y
2					
3					
4					
5					
6					
7	7.75				Y
8					
9	7.67				Y
10					
11					
12					
13					
14	7.57				Y
15					
16	7.51				Y
17					
18					
19					
20					
21	7.31				Y
22					
23	7.45				Y
24					
25					
26					
27					
28	7.61				Y
29					
30					
31	7.91				Y

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT
EP-A**

**PWS ID 4194717
COLUMBIA RIVER PUD**

Sample period: Jan 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Gregory A Hollis

Signature: Gregory A Hollis

Date & Phone#: 2/4/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0