

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.98				
3					
4					
5					
6					
7					
8	7.94				
9					
10	7.86				
11					
12					
13					
14					
15	7.74				
16					
17	7.70				
18					
19					
20					
21					
22	7.76				
23					
24	7.78				
25					
26					
27					
28					
29	7.78				
30					
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4194717

COLUMBIA RIVER PUD

Sample period: 4/2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Greg A Hollis

Signature: Greg A Hollis

Date & Phone#: 5/1/2025 503-396-0529

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0