

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.39				Y
3	7.39				Y
4					
5					
6					
7					
8	7.40				Y
9					
10					
11					
12					
13					
14	7.30				Y
15					
16	7.58				Y
17					
18					
19					
20					
21	7.84				Y
22					
23	7.89				Y
24					
25					
26					
27					
28	7.80				Y
29					
30	7.61				Y
31					

(No = N = Excursion) **Total N's**

<<Have  
minimums  
been met for  
this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**

EP-A

**PWS ID 4194717**

**COLUMBIA RIVER PUD**

**Sample period:** October 2025

Month/Year

**Number of excursions during this month:** 8

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH

**Print Name:** Gregory A Hollis

**Signature:** Gregory A Hollis

**Date & Phone#:** 9-4-25 503-396-0529

Send to DWP within 10 days after end of  
sampling period