

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.49				
7					
8					
9					
10					
11					
12					
13	7.42				
14					
15					
16					
17					
18					
19					
20	7.43				
21					
22					
23					
24					
25					
26					
27	7.41				
28					
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 9 4 7 6 5

System Name: Becklin Holdings

Entry Point: EP-A

Sample Period: October 2025

Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only _____

**Minimum Water Quality
Parameters as set by**

pH	<input type="checkbox"/>	
Alk	<input type="checkbox"/>	(Alkalinity)
PO4	<input type="checkbox"/>	(Orthophosphate)
Other	<input type="checkbox"/>	(_____)

Print Name: Carmell Bassoni

Signature: 

Date: 7/27/2025

Send to DWP within 10 days after end of sampling period