

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.38				
6					
7					
8					
9					
10					
11					
12	7.23				
13					
14					
15					
16					
17					
18					
19	7.2				
20					
21					
22					
23					
24					
25					
26	7.30				
27					
28					
29					
30					
31					

ENTRY POINT

<<Have minimums been met for this day? PWS ID: 41

System Name: Becklin Holdings

Entry Point: EP-A

Sample Period: January 2026
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value=""/>	
Alk	<input type="text" value=""/>	(Alkalinity)
PO4	<input type="text" value=""/>	(Orthophosphate)
Other	<input type="text" value=""/>	(_____)

Print Name: Carmell Bassoni

Signature: *Carmell Bassoni*

Date: 01/26/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**