

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1					
2					
1 2 3 4					
4	7.49				Y
5	7.49				Y
6					
7					
8					
9					
10	7.71				Y
11					
12	7.49				Y
13					
14					
15					
16					
17					
18	7.89				Y
19					
20	775				7
21					
22					
23					
24					
25	7.82				Y
26					
27	802				Y
28					1
29					
30					
31					

<<Have minimums been met for this day?

County: Linn

Agency: LINN COUNTY

ENTRY POINT

EP-A

PWS ID 4194865

EASTGATE CENTER

Sample period: He

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

ΡH 7.2

Print Name:

Signature:

Date & Phone#:

Send to DWP within 10 days after end of

sampling period