

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	6.85				Y
2					
3					
4					
5					
6					
7	6.90				Y
8					
9					
10	6.80				Y
11					
12					
13					
14					
15	6.66				Y
16					
17					
18					
19					
20					
21					
22	7.98				N
23					
24					
25					
26					
27					
28	6.86				Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 94865

System Name: EASTGAR Business Center

Entry Point: EP-A

Sample Period: February 2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Brian Tarkenton

Signature: _____

Date: 3/8/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 1