

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.6				Y
3					
4	7.8				Y
5					
6					
7	7.8				Y
8					
9					
10					
11					
12	8.4				Y
13					
14	8.6				Y
15					
16					
17					
18	8.3				Y
19					
20					
21					
22	8.1				Y
23					
24					
25					
26					
27	8.2				Y
28					
29					
30	8.1				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Eastgate Business Center

Entry Point: EP-A

Sample Period: April 2022

Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other

Print Name: Brian Tarkenton
Signature: [Signature]
Date: 5/9/2022

Send to DWP within 10 days after end of sampling period