

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.89				Y
4					
5	7.92				Y
6					
7					
8					
9	7.88				Y
10					
11	7.90				Y
12					
13					
14					
15					
16	7.82				Y
17					
18	8.02				Y
19					
20					
21					
22					
23	7.93				Y
24					
25					
26					
27	7.92				Y
28					
29					
30					
31	7.93				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Eastgate Center

Entry Point: EP-A

Sample Period: MAY 2022
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Brian Tarkenton

Signature: [Signature]

Date: 06/07/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's