

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.89				Y
6					
7					
8					
9					
10					
11					
12	7.05				N
13					
14					
15	7.40				Y
16					
17					
18					
19	8.50				Y
20					
21					
22	8.65				Y
23					
24					
25	7.86				Y
26	8.39				Y
27					
28					
29	7.86				Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 94865

System Name: Eastgate Business Center

Entry Point: EP-A

Sample Period: JULY 2022
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Brian Tarkenton

Signature:

Date: 8/8/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 1