

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2					
3					
4	8.0				Y
5					
6					
7					
8	7.5				Y
9	7.5				Y
10					
11					
12					
13					
14					
15	8.9				Y
16					
17					
18	8.3				Y
19					
20					
21					
22					
23					
24	7.2				
25					
26	6.2				N
27					
28					
29	7.2				
30	6.2				N
31	6.2				N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 94865

System Name: Eastgate Center

Entry Point: EP-A

Sample Period: August 2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: _____

Signature: _____

Date: _____

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 3