



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2					
3					
4					
5					
6	7.4				Y
7					
8					
9	7.4				Y
10					
11					
12					
13	7.4				Y
14					
15	7.4				Y
16					
17					
18					
19					
20	7.3				Y
21					
22					
23	7.3				Y
24					
25	7.06				N
26					
27					
28					
29	7.10				
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 94865

System Name: Eastgate Business Center

Entry Point: EP-A

Sample Period: September 2022
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Brian Tarkenton

Signature: *[Signature]*

Date: 10/06/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 6