



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.25				Y
4					
5					
6	7.27				Y
7					
8					
9					
10	7.26				Y
11					
12					
13	7.27				Y
14					
15					
16					
17					
18	7.28				Y
19					
20	7.24				Y
21					
22					
23					
24	7.26				Y
25					
26	8.23				Y
27	8.24				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Linn Agency: LINN COUNTY

**ENTRY POINT**  
**EP-A**  
**PWS ID 4194865**  
**EASTGATE CENTER**

Sample period: July 2023  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Brian Tarkenton  
Signature: [Signature]  
Date & Phone#: 8/9/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0